



AMERICAN INSTITUTE OF TIMBER CONSTRUCTION

7012 South Revere Parkway, Suite 140 · Englewood, Colorado 80112 · Telephone 303-792-9559

AITC 108-93

STANDARD FOR HEAVY TIMBER CONSTRUCTION

Errata

May 9, 2002

Subsequent to the printing of AITC 108-93, errors were discovered in section 4. The following paragraph shows the correct wording and supercedes the wording in AITC 108-93.

4. HEAVY TIMBER ROOF DECKS

4.1 Roof decks shall be of (1) sawn or glued laminated planks, splined or tongue-and-groove, not less than 2 in., nominal, in thickness, (2) 1-1/8 in. thick tongue-and-groove interior plywood (exterior glue), or (3) planks, not less than 3 in., nominal, in width, set on edge close together and laid as required for floors. Other wood and/or wood-fiber based decking or other types of decking may be used if noncombustible.